



### OFFICIAL LISTING

NSF International Certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI Standard 61 - Drinking Water System Components - Health Effects

This is the Official Listing recorded on May 7, 2008.

GODFREY & WING, INC.  
220 CAMPUS DRIVE  
AURORA, OH 44202  
330-562-1440

Facility: AURORA, OH

#### Joining and Sealing Materials

Trade Designation	Size	Water Contact Temp	Water Contact Material
Sealant Imprex 95-1000A	[1]	C. HOT	SLT

[1] Certified for a maximum surface area to volume ratio of 50 sq. in./L. Certified for use with brass materials having no greater than 12% porosity.